



RECEIVED

FEB 24 2015

PUBLIC SERVICE
COMMISSION

February 20, 2015

Mr. Jeff Derouen, Executive Director
Kentucky Public Service Commission
211 Sower Boulevard
Frankfort, KY 40601

RE: Sample Meter Test Plan – Annual Report
Case No. 2004-00121

Dear Mr. Derouen:

Atmos Energy Corporation (Company) herewith submits its 2014 annual report for the Sample Meter Testing Program to be in compliance with the Commission's Order in the above referenced case. The Company continues to be pleased with the results of this program.

Please contact myself at 270.685.8024 or Bruce Tucker and 270.685.8137 if the Commission or Staff has any questions regarding the enclosed report.

Sincerely,

A handwritten signature in black ink that reads "Mark A. Martin". The signature is written in a cursive style.

Mark A. Martin
Vice President, Rates & Regulatory Affairs

cc: Joel Grugin
Ernie Napier
Bruce Tucker

Enclosures



February 17, 2014

ATMOS ENERGY KENTUCKY DIVISION
2014 METER SAMPLING ANNUAL REPORT

Atmos Energy, Kentucky Division completed the 16th year of its statistical sampling of their meter population with following results:

A total of 3,958 meters were sampled, as set forth in the Kentucky Public Service Commission's Order (Case Number 99-059), dated August 24, 1999.

The meter sampling program continues to be excellent for both, the company and our customers, identifying poor performing meters and allowing quality meters to remain in service for an extended length of time.

Included are the results of the 2014 Meter Sampling Program. The results spreadsheet indicates that all meter groups passed. Additionally, 1,458 obsolete meters were removed from service and retired.

Pease feel free to contact me if you have any additional questions.

Respectfully,

A handwritten signature in black ink that reads "Bruce Tucker". The signature is written in a cursive style.

Bruce Tucker
Manager, Compliance

2014 METER SAMPLING PROGRAM

Family Group	Description	Meters Sampled	Meters Failed	Failures Allowed	Total meters in Family	Status
AC250C	1978-1988	125	4	14	1783	PASSED
AC250D	1989-1993	200	3	21	7993	PASSED
AC250E	1994,1996,1997	200	2	21	7587	PASSED
AC250F	1995	200	0	21	7542	PASSED
AC250G	1998	200	5	21	6319	PASSED
AC250H	1999-2002	200	0	21	5779	PASSED
AC250I	2003	200	19	21	7628	PASSED
AC250J	2004	200	21	21	9987	PASSED
AL175A	1970-1975	125	0	14	2956	PASSED
AL175B	1976-1982	200	0	21	5190	PASSED
AL175C	1982-1990	125	1	14	2747	PASSED
AL175D	1990-2003	200	8	21	8493	PASSED
AL425A	1975-1995	80	0	10	560	PASSED
AL425B	1996-2004	125	3	14	1499	PASSED
L250	All	125	7	14	1722	PASSED
R175	1973-2003	125	6	14	1876	PASSED
R200A	1974-1984	200	9	21	4997	PASSED
R200B	1984-2003	125	3	14	2227	PASSED
R275A	1984-1989	125	5	14	1635	PASSED
R275B	1989-1992	125	8	14	2147	PASSED
R275C	1996	125	2	14	2035	PASSED
R275D	1997	200	12	21	6851	PASSED
R275E	1998-2003	200	9	21	9136	PASSED
AL800	All	32	2	5	265	PASSED
AL1000	All	50	5	7	305	PASSED
R750	All	13	2	2	51	PASSED
R415	All	8	1	1	27	PASSED
S250	All	125	0	14	1481	PASSED
Obsoletes	ALL	1458	N/A	N/A	N/A	N/A

TOTAL	5416
--------------	-------------